



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

GAF

**1361 Alps Road
Wayne, NJ 07470**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF Ruberoid® Modified Bitumen Roof System for Steel Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 13-0409.06 and consists of pages 1 through 110.

The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 13-1022.16
Expiration Date: 11/06/15
Approval Date: 10/16/14
Page 1 of 110**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen
Material: SBS/APP
Deck Type: Steel
Maximum Design Pressure: -120 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
GAFGlas® Ply 4	39.37" (1 meter) Wide	ASTM D2178	A smooth surfaced asphaltic ply sheet reinforced with fiberglass mat.
Tri-Ply® Ply 4	39.37" (1 meter) Wide	ASTM D2178	A smooth surfaced asphaltic ply sheet reinforced with fiberglass mat.
GAFGlas® FlexPly™ 6	39.37" (1 meter) Wide	ASTM D2178	A smooth surfaced asphaltic ply sheet reinforced with fiberglass mat.
GAFGlas® #75 Base Sheet	39.37" (1 meter) Wide	ASTM D4601	Type II asphalt impregnated and coated glass mat base sheet.
Tri-Ply® #75 Base Sheet	39.37" (1 meter) Wide	ASTM D4601	A smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
GAFGlas® #80 Ultima™ Base Sheet	39.37" (1 meter) Wide	ASTM D4601	A smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
GAFGlas® Stratavent® Eliminator™ Perforated Venting Base Sheet	39.37" (1 meter) Wide	ASTM D4897	A smooth surfaced asphaltic perforated venting base sheet reinforced with fiberglass mat.
GAFGlas® Stratavent® Eliminator™ Nailable Venting Base Sheet	39.37" (1 meter) Wide	ASTM D4897	A smooth surfaced asphaltic nailable venting base sheet reinforced with fiberglass mat. Bottom side surfaced with granules.
GAFGlas® Mineral Surfaced Cap Sheet	39.37" (1 meter) Wide	ASTM D3909	A granule surfaced asphaltic cap sheet reinforced with fiberglass mat.
Tri-Ply® Mineral Surfaced Cap Sheet	39.37" (1 meter) Wide	ASTM D3909	A granule surfaced asphaltic cap sheet reinforced with a fiberglass mat.
GAFGlas® EnergyCap™ BUR Mineral Surfaced Cap Sheet	39.37" (1 meter) Wide	ASTM D3909	A granule surfaced asphaltic cap sheet reinforced with fiberglass mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
WeatherWatch® XT Mat Surfaced Leak Barrier	36" x 50' Rolls 36" x 66.7' Rolls	ASTM D1970	Mat surfaced SBS modified, fiberglass reinforced, bituminous sheet material for use as a leak barrier underlayment or vapor retarder



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
UnderRoof™ 2 Polyester-Surfaced Leak Barrier	39 3/8" x 67.8' Rolls	ASTM D1970	Self-adhering reinforced membrane of SBS modified asphalt with polyester surfacing for use as a leak barrier underlayment or vapor retarder.
UnderRoof™ HT High Temperature Leak Barrier	39 3/8" x 61' Rolls	ASTM D1970	Self-adhering SBS membrane with a top surface and reinforcement consisting of a coated polyester mat for use as a leak barrier underlayment or vapor retarder.
Ruberoid® SBS Heat-Weld 25	39.37" (1 meter) Wide	ASTM D6163	A smooth surfaced torch applied SBS base or ply sheet reinforced with a fiberglass mat.
Ruberoid® SBS Heat-Weld Smooth	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced torch applied SBS base or ply sheet reinforced with a polyester mat.
Ruberoid® SBS Heat-Weld Granule	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced torch applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® SBS Heat-Weld 170 FR	39.37" (1 meter) Wide	ASTM D6164	A fire retardant granule surfaced heat-welded SBS cap sheet reinforced with a polyester mat.
Ruberoid® SBS Heat-Weld Plus	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced torch applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® SBS Heat-Weld Plus FR	39.37" (1 meter) Wide	ASTM D6164	A fire retardant granule surfaced torch applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR	39.37" (1 meter) Wide	ASTM D6164	A fire retardant granule surfaced heat-welded SBS cap sheet reinforced with a polyester mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
Ruberoid® Torch Smooth	39.37" (1 meter) Wide	ASTM D6222	A smooth surfaced torch applied APP base or ply sheet reinforced with a polyester mat.
Tri-Ply® TP-4	39.37" (1 meter) Wide	ASTM D6222	A smooth surfaced torch applied APP cap, base or ply sheet reinforced with a polyester mat.
Ruberoid® Torch Granule	39.37" (1 meter) Wide	ASTM D6222	A granule surfaced torch applied APP cap sheet reinforced with a polyester mat.
Ruberoid® Torch 180	39.37" (1 meter) Wide	ASTM D6222	A granule surfaced torch applied APP cap sheet reinforced with a polyester mat.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
RoofMatch™ APP Modified Granular	39.37" (1 meter) Wide	ASTM D6222	A granule surfaced torch applied APP cap sheet reinforced with a polyester mat.
Tri-Ply® TP-4G	39.37" (1 meter) Wide	ASTM D6222	A granule surfaced torch applied APP cap sheet reinforced with a polyester mat.
Ruberoid® Torch FR	39.37" (1 meter) Wide	ASTM D6222	A fire retardant granule surfaced torch applied APP cap sheet reinforced with a polyester mat.
Ruberoid® EnergyCap™ Torch Plus FR	39.37" (1 meter) Wide	ASTM D6222	A fire retardant granule surfaced torch applied APP cap sheet reinforced with a polyester mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
Ruberoid® EnergyCap™ Torch Granule FR	39.37" (1 meter) Wide	ASTM D6222	A fire retardant granule surfaced torch applied APP cap sheet reinforced with a polyester mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
Ruberoid® 20	39.37" (1 meter) Wide	ASTM D6163	A SBS polymer-modified asphalt base or ply sheet reinforced with a fiberglass mat.
Ruberoid® 30	39.37" (1 meter) Wide	ASTM D6163	A granule surfaced mop applied SBS cap sheet reinforced with a fiberglass mat.
Ruberoid® 30 FR	39.37" (1 meter) Wide	ASTM D6163	A fire retardant granule surfaced mop applied SBS cap sheet reinforced with fiberglass mat.
Ruberoid® Mop Granule	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
Tri-Ply® SBS Modified Bitumen Membrane	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
RoofMatch™ SBS Modified Granular	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
Intec Flex PRF	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® Mop Smooth	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced mop applied SBS base sheet reinforced with a polyester mat.
Ruberoid® Mop Smooth 1.5	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced mop applied SBS base sheet reinforced with a polyester mat.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Ruberoid® Mop Plus Smooth	39.37" (1 meter) Wide	ASTM D6164	A smooth surfaced mop applied SBS base or ply sheet reinforced with a polyester mat.
Ruberoid® Mop Plus	39.37" (1 meter) Wide	ASTM D6164	A granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® Mop FR	39.37" (1 meter) Wide	ASTM D6164	A fire retardant granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® EnergyCap™ Mop FR	39.37" (1 meter) Wide	ASTM D6164	A fire retardant granule surfaced mop applied SBS cap sheet reinforced with a polyester mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
Ruberoid® Mop 170 FR	39.37" (1 meter) Wide	ASTM D6164	A fire retardant granule surfaced mop applied SBS cap sheet reinforced with a polyester mat.
Ruberoid® EnergyCap™ 30 FR SBS Membrane	39.37" (1 meter) Wide	ASTM D6163	A fire retardant granule surfaced mop applied SBS cap sheet reinforced with a fiberglass mat. Cap sheet is factory coated with Topcoat® EnergyCote™ Elastomeric Coating.
Matrix™ 102 SBS Membrane Adhesive	5 Gallons	ASTM D3019	Fiber reinforced rubberized cold-applied adhesive for modified bitumen roof systems.
Topcoat® Membrane	1, 5 Or 55 Gallons	ASTM D6083	Acrylic, water based elastomeric membrane system designed to protect various types of roof surfaces.
Topcoat® MB Plus	5 Or 55 Gallons	Proprietary	Water based, low VOC primer designed to block asphalt bleed-through.
Topcoat® Surface Seal SB	5 Gallons	ASTM D6083	Solvent based sprayable thermoplastic rubber sealant designed to protect and restore aged roof surfaces and to increase roof reflectivity.

APPROVED INSULATIONS:

TABLE 2		
Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard™ Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ HD Polyiso Insulation	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ HD Plus Polyiso Insulation	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RH Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RN Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ Perlite Roof Insulation	Perlite insulation board.	GAF
EnergyGuard™ Perlite Recover Board	Perlite recover board	GAF
DensDeck® Roof Board	Gypsum board	Georgia-Pacific Gypsum LLC
DensDeck® Prime® Roof Board	Gypsum board	Georgia-Pacific Gypsum LLC
DensDeck® DuraGuard® Roof Board	Gypsum board	Georgia-Pacific Gypsum LLC
Securock® Gypsum-Fiber Roof Board	Gypsum board	United States Gypsum Corp.
Securock® Glass-Mat Roof Board	Gypsum board	United States Gypsum Corp.

APPROVED FASTENERS:

TABLE 3				
Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Drill-Tec™ #12 Fastener	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating. Available with a pinch point or drill point.	#12 X 8" Max. Length, #3 Phillips Head	GAF
2.	Drill-Tec™ #14 Fastener	Truss head, self-drilling, pinch point, high thread fastener for use in steel, wood or concrete decks.	#14 X 16" Max. Length, #3 Phillips Head.	GAF
3.	Drill-Tec™ ASAP 3S	Drill-Tec™ #12 Fastener with Drill-Tec™ 3" Standard Steel Plate.	See Components	GAF



APPROVED FASTENERS:**TABLE 3**

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
4.	Drill-Tec TM AccuTrac [®] Flat Plate	A2-SS aluminized steel plate for use with Drill-Tec TM fasteners.	3" Square; .017" Thick	GAF
5.	Drill-Tec TM AccuTrac [®] Recessed Plate	Galvalume [®] steel plate with recess for use with Drill-Tec TM fasteners.	3" Square; .017" Thick.	GAF
6.	Drill-Tec TM 3" Steel Plates	Round Galvalume [®] steel stress plate with reinforcing ribs and recessed for use with Drill-Tec TM fasteners.	3" Round	GAF
7.	Drill-Tec TM 3" Standard Steel Plate	Galvalume [®] coated steel stress plate for use with approved Drill-Tec TM fasteners.	3" Round	GAF
8.	Drill-Tec TM 3 in. Ribbed Galvalume Plate (Flat)	Round Galvalume [®] plated steel stress plate with reinforcing ribs for use with Drill-Tec TM fasteners.	3" Round	GAF
9.	Drill-Tec TM 2 in. Double Barbed XHD Plate	Round galvanized steel stress plates for use with Drill-Tec TM fasteners.	2" Round	GAF
10.	Drill-Tec TM 2-3/8 in. Barbed XHD Plate	Round galvanized steel stress plates for use with Drill-Tec TM fasteners.	2-3/8" Round	GAF
11.	Drill-Tec TM Eyehook Accuseam Plates	Galvalume [®] coated steel 3" Square	3"	GAF
12.	Drill-Tec TM Batten Bar	A corrosion-free polymer used to secure single-ply membrane to steel, wood and structural concrete roof decks.	3/4" or 1"	GAF

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	1B9A8.AM	Class 4470	09/04/97
	3D4Q2.AM	Class 4470	04/30/97
	3001276	Class 4470	01/28/99
	3001276	Class 4470	01/28/99
	3007500	Class 4470	06/15/00
	3011140	Class 4470	08/14/01
	3011140	Class 4470	08/14/01
	3013788	Class 4470	01/10/03
	3014547	Class 4470	05/22/03
	3014547	Class 4470	05/22/03
	3017250	Class 4470	04/05/04
	3023458	Class 4450	07/18/06
	3031350	Class 4470	09/27/07
	3032811	Class 4470	12/11/08
	3033719	Class 4470	12/24/08
	3035864	Class 4470	06/03/09
	3036614	Class 4470	06/09/09
	3036980	Class 4470	08/14/09
	3040738	Class 4470	05/31/11
	3041005	Class 4470	05/18/12
	3042887	Class 4470	11/14/11
	3043633	Class 4470	01/20/12
	3043900	Class 4470	08/16/12
	3044541	Class 4470	04/04/12
	3044862	Class 4470	05/11/12
	3046388	Class 4470	09/24/12
	3047104	Class 4470	08/29/13
	3048122	Class 4470	04/29/13
	3048496	Class 4470	12/19/13
	3048496	Class 4470	12/19/13
	3048871	Class 4470	12/11/13
	3049601	Class 4470	01/29/14
Underwriters Laboratories, Inc.	R1306	UL 790	07/22/13
	04-0041	TAS-114	01/26/04
Momentum Technologies, Inc.	EX14A3A	ASTM D6083	02/26/04
Trinity Engineering	4483.04 97-1	TAS-114	06/06/97
	C8500SC.11.07	TAS-117	11/30/07
Trinity ERD	G30250.02.10-2	ASTM D6222	02/11/10
	G30250.02.10-3-R1	ASTM D3909	02/15/10
	G31360.03.10	ASTM D6164	03/31/10
	G3250.06.11	ASTM D1967	06/28/11
	G33470.01.11	ASTM D6164	01/13/11
	G34140.04.11-2	ASTM D6163	04/25/11
	G34140.04.11-4	ASTM D4601	04/25/11
	G34140.04.11-5-R1	ASTM D4897	04/25/11

EVIDENCE SUBMITTED: (CONTINUED)

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Trinity ERD	G40620.07-12-2	ASTM D6222	07/17/12
	G40630.01.14	ASTM D6164	03/06/14
	G40630.01.14-1	ASTM D6163	01/06/14
	G40630.01.14-2A	ASTM D6164	01/07/14
	G40630.01.14-2A-1	ASTM D6164	01/07/14
	G40630.01.14-2B	ASTM D6164	01/07/14
	G40630.01.14-2C	ASTM D6164	01/07/14
	G40630.03.14	ASTM D6164	03/06/14
	G43190.03.14-1	ASTM D6222	03/06/14
	G43190.03.14-2	ASTM D6222	03/06/14
	G43190.05.14-R1	ASTM D6222	05/20/14
	G43190.11.13-1	ASTM D222	11/15/13
	G43610.01.14	ASTM D3909	01/22/14
	G6850.08.07-1	ASTM D3909	08/13/07
	G6850.08.08	ASTM D6163	08/01/08
	G6850.08.08-R1	ASTM D6164	04/14/11
	G6850.10.08	ASTM D6222	10/06/08
	G6850.11.08	ASTM D6222	11/05/08
PRI Construction Materials Technologies LLC	GAF-328-02-01	ASTM D1970	03/03/11
	GAF-344-02-01	ASTM D1970	04/23/12
	GAF-275-02-01	ASTM D1970	11/11/11
	GAF-082-02-01	ASTM D6083	05/07/06
	GAF-084-02-01	ASTM D6083	05/07/06
	GAF-314-02-01	ASTM D2178	08/23/11
	GAF-315-02-01	ASTM D2178	08/23/11
	GAF-238-02-01	ASTM D1970	03/03/10
	GAF-209-211-02-01	ASTM D6083	05/05/09
	GAF-343-02-01	ASTM D1970	04/23/12
	GAF-369-02-01	ASTM C1289	10/23/12
	GAF-411-02-01	ASTM C1289	05/02/13
	GAF-412-02-01	ASTM C1289	05/02/13
	GAF-436-02-01	ASTM D1876	03/05/14
	GAF-436-02-02	TAS-114	03/05/14
	GAF-436-02-03	TAS-114	03/05/14
	GAF-436-02-04	TAS-114	03/05/14
	GAF-436-02-05	TAS-114	03/05/14
	GAF-436-02-08	TAS-114	03/05/14
	GAF-436-02-09	TAS-114	03/05/14
	GAF-464-02-01	ASTM C1289	02/05/14
	GAF-499-02-01	ASTM D6083	03/12/14
	GAF-500-02-01	ASTM D6083	03/12/14

APPROVED ASSEMBLIES

Membrane Type: APP/SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18-22 ga. steel Type B Grade E steel decking attached to steel supports spaced 6 ft. o.c. with Buildex Traxx/4 or 5 fasteners spaced 6" o.c. (at the bottom flute), and with side laps attached with Buildex Traxx/1 fasteners spaced at max. of 30" o.c.

System Type B(1): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 2" thick	1, 2, & 6	1:1.45 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation, EnergyGuard™ Perlite Recover Board, Securock® Gypsum-Fiber Roof Board, DensDeck® DuraGuard® Roof Board, DensDeck® Prime® Roof Board Minimum 1" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Ply Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, (Optional) GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

- Membrane:** One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Granule, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.
- OR
- Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
- OR
- One or more plies of Ruberoid® SBS Heat-Weld 25, Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied in accordance with manufacturer's instructions.
- Surfacing:** **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**
1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
 2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
 3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5gal./sq.
- Maximum Design Pressure:** -60 psf. (See General Limitation #7.)

- Membrane Type:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** Minimum 18-22 ga. steel Type B Grade 80 steel decking secured to minimum 1/4" steel supports spaced 6 ft. o.c. with Buildex Traxx/4 or 5 fasteners spaced 6" o.c. (at the bottom flute), and with side laps attached with Buildex Traxx/1 fasteners spaced at max. of 24" o.c.
- System Type B(2):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.
- Thermal Barrier:** Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 6, 7	1:1.3 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation, Securock® Gypsum-Fiber Roof Board, EnergyGuard™ Perlite Recover Board, DensDeck® DuraGuard® Roof Board, DensDeck® Prime® Roof Board Minimum 1/2" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Ply Sheet: (Required when Mineral Surfaced Cap Sheets are used.)
(Optional) One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20 Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Or

(Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).) GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -90 psf. (See General Limitation #7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel, 33 ksi

System Type B(3): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:4 ft²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: (Optional) **(Required when Mineral Surfaced Cap Sheets are used.)**
One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20 Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

- Membrane:** One or more plies of Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.
- Or
- (Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).)** GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Surfacing:** **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS/APP

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel, 33 ksi

System Type B(4): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

All General and System limitations apply.

Base Insulation Layer / Thermal Barrier	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 0.5" thick	1, 2, 3, 4, 7	1:2.7 ft ²

Note: Base Insulation Layer / Thermal Barrier shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: UnderRoof™ 2 Polyester-Surfaced Leak Barrier or UnderRoof™ HT High Temperature Leak Barrier is self-adhered to the Base Insulation (thermal barrier) and rolled with a weighted roller.

Middle Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RA Tapered Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RH Tapered Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ RN Tapered Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Insulation is adhered to the vapor barrier with OlyBond 500® or Olybond 500® Green applied in 0.75 – 1 in wide ribbons spaced 12 in. o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: Optional top insulation is adhered to the insulation with Olybond 500® or Olybond 500® Green applied in 0.75 – 1 in wide ribbons spaced 12 in. o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: Apply one layer of WeatherWatch® XT Mat Surfaced Leak Barrier self-adhered with minimum 3" wide laps and rolled with a weighted roller.

Membrane: One or more plies of Ruberoid® SBS Heat-Weld 25, Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR with minimum 3” wide laps and torch adhered in accordance with manufacturer's instructions.

Or

Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR with minimum 3” wide laps and torch adhered in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel, 33 ksi

System Type B(5): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board
 or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²
EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:3.2 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Additional layer(s) of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation Minimum 3/4" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard, EnergyGuard™ Perlite Recover Board Minimum 1/2" thick	N/A	N/A
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
 OR
 One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel Type B Grade 33 steel decking attached to steel supports spaced 6 ft. o.c. with ICH Traxx/4 or 5, Teks 4 or Teks 5 fasteners spaced 6" o.c. and with side laps attached with Buildex Traxx/1 or Teks 1 fasteners spaced at max. of 24" o.c..

System Type B(6): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:1.33 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Additional layer(s) of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation Minimum 3/4" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard, EnergyGuard™ Perlite Recover Board Minimum 1/2" thick	N/A	N/A
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type B(7): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:3.2 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation Minimum 3/4" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard, EnergyGuard™ Perlite Recover Board Minimum 1/2" thick	N/A	N/A
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.



Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type B(8): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:3.2 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Recover Board Minimum 1/2" thick	N/A	N/A
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, GAFGLAS® FlexPly™ 6 or Tri-Ply® Ply 4 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

OR

One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type B(9): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board
or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2.67 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation Minimum 3/4" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard Minimum 1/2" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, or Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type:	SBS
Deck Type 2I:	Steel, Insulated
Deck Description:	Minimum 22 ga., 33 ksi.
System Type B(10):	Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.
Thermal Barrier: (Optional)	Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:4 ft²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation Minimum 3/4" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard, EnergyGuard™ Perlite Recover Board Minimum 1/2" thick	N/A	N/A
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet:	Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions. OR One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
Membrane:	Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel Type B Grade 33 steel decking attached to steel supports spaced 6 ft. o.c. with ICH Traxx/4 or 5, Teks 4 or Teks 5 fasteners spaced 6" o.c. and with side laps attached with ICH Traxx/1 or Teks 1 fasteners spaced at max. of 24" o.c.

System Type B(11): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:1.33 ft ²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation Minimum 3/4" thick	N/A	N/A
Structodek® High Density Fiberboard Roof Insulation, EnergyGuard™ Perlite Recover Board Minimum 1/2" thick	N/A	N/A
DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board, Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheets: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

OR

One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® 30 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7)

Membrane Type:	SBS
Deck Type 2I:	Steel, Insulated
Deck Description:	Minimum 22 ga. steel Type B Grade 33 steel decking attached to steel supports spaced 6 ft. o.c. with ICH Traxx/4 or 5, Tek's 4 or Tek's 5 fasteners spaced 6" o.c. and with side laps attached with ICH Traxx/1 or Tek's 1 fasteners spaced at max. of 24" o.c.
System Type B(12):	Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.
Thermal Barrier: (Optional)	Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:1.6 ft²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Securock® Gypsum-Fiber Roof Board Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet:	One ply of Ruberoid® SBS Heat-Weld Smooth or Ruberoid® SBS Heat-Weld 25, torch-applied in accordance with manufacturer's instructions.
Ply Sheet: (Optional)	One ply of Ruberoid® SBS Heat-Weld Smooth or Ruberoid® SBS Heat-Weld 25, torch-applied in accordance with manufacturer's instructions.
Membrane:	One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR, Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied in accordance with manufacturer's instructions. Or One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel Type B Grade 33 steel decking attached to steel supports spaced 6 ft. o.c. with ICH Traxx/4 or 5, Teks 4 or Teks 5 fasteners spaced 6" o.c. and with side laps attached with ICH Traxx/1 or Teks 1 fasteners spaced at max. of 24" o.c.

System Type B(13): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation		
Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:1.6 ft²

Note: Base layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Securock® Gypsum-Fiber Roof Board		
Minimum 1/4" thick	N/A	N/A

Note: Top layer of insulation shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Base Sheet: One ply of Ruberoid® Torch Smooth or Tri-Ply® TP-4, torch-applied in accordance with manufacturer's instructions.

Ply Sheet: (Optional) One ply of Ruberoid® Torch Smooth or Tri-Ply® TP-4, torch-applied in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18-22 ga. steel Type B Grade 33 steel decking attached to steel supports spaced 6 ft. o.c. with Buildex Traxx/4 or 5 fasteners spaced 6" o.c. (at the bottom flute), and with side laps attached with Buildex Traxx/1 fasteners spaced at max. of 24" o.c.

System Type C(1): Base sheet loose laid dry ; both layers of insulation simultaneously fastened.

All General and System limitations apply.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Both layers shall be simultaneously attached; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck® Roof Board Minimum 0.25" thick	1 & 7	1:1 ft²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: **(Required when Heat-Weld or Torch Membranes or Mineral Surfaced Cap Sheets are used.)** One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20 Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Or

(Required to only use with ply sheet(s).) One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied or applied with an approved hot air welder in accordance with manufacturer's instructions.

Or

(Required to only use with ply sheet(s).) One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.

Or

(Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).) GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5gal./sq.

Maximum Design

Pressure: -82.5 psf. (See General Limitation #7.)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge steel non-vented B-deck, grade 33, attached to 5' o.c. bar joist with puddle welds and washers at 6" o.c. and side laps with tech screws at 12" o.c.

System Type C(2): Base sheet loose laid; insulation mechanically fastened.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	1 & 6	1:1.45 ft²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: GAFLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2 in. side laps.

Ply Sheet: One or more plies Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions

Membrane: One or more plies of Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Or

One or more plies of Ruberoid® SBS Heat-Weld 25, Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR applied in accordance with manufacturer's instructions.

Or

(Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).) GAFLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7.)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge steel, grade 33, secured to minimum ¼ " (6 mm) thick steel structural supports 6 ft. (1.8m) o.c. with ITW Buildex TRAXX/5 fasteners 6 in. (1.52) o.c. along the center of the supports. Deck side laps are secured 24 in. (610 mm) o.c. with ITW Buildex TRAXX/1 fasteners.

System Type C(3): All insulation simultaneously fastened. Base sheet adhered to insulation.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® (Optional) DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 2" thick	N/A	N/A

Note: Both layers shall be simultaneously attached; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Securock® Gypsum-Fiber Roof Board Minimum 0.5" thick	1, 2, 6, 7	1:1.78 ft²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. and broomed in.
Or
One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid 20, Ruberoid Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Smooth Plus adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Or

One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied in accordance with manufacturer's instructions.

Or

(Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).) GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7)

Membrane Type: APP/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel deck, grade 80, secured to 0.25 in. thick structural supports spaced 6' o.c. using two ICH Traxx/5 fasteners and 0.75 in. washers spaced 6 in. o.c. along each support. The deck side laps were fastened with ICH Traxx/1 fasteners spaced at 12 in. o.c. along each side lap.

System Type C(4): Base insulation loose laid; top layer of insulation is mechanically fastened.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of each of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, , EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Both layers shall be simultaneously attached; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Securock® Gypsum-Fiber Roof Board Minimum 0.5" thick	1 & 6	1:1 ft ²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One or more plies of Ruberoid® SBS Heat-Weld 25 or Ruberoid® SBS Heat-Weld Smooth torch adhered with 3 in. wide side laps in accordance with manufacturer's instructions.

Membrane: Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch adhered with 3 in. wide side laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5gal./sq.

Maximum Design

Pressure: -120 (See General Limitation # 7)

Membrane Type: SBS/APP

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel, 33 ksi

System Type C(5): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: 0.5" DensDeck® DuraGuard® Roof Board, DensDeck® Prime® Roof Board or Securock® Gypsum-Fiber Roof Board or Securock® Glass-Mat Roof Board, loose laid.

Vapor Retarder: WeatherWatch® XT Mat Surfaced Leak Barrier, UnderRoof™ 2 Polyester-Surfaced Leak Barrier or UnderRoof™ HT High Temperature Leak Barrier is self-adhered to the thermal barrier and rolled with a weighted roller.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	1, 2, 4, 5, 6, 7, 8	1:2 ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2, 4, 5, 6, 7, 8	1:4 ft²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One layer of WeatherWatch® XT Mat Surfaced Leak Barrier self-adhered with minimum 3" wide laps and roll with a weighted roller.

Membrane: One or more plies of Ruberoid® SBS Heat-Weld 25, Ruberoid® SBS Heat Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR, Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR with minimum 3" wide laps and torch adhered in accordance with manufacturer's instructions.

Or

Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR with minimum 3" wide laps and torch adhered in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

- Membrane Type:** SBS/APP
- Deck Type 2I:** Steel, Insulated
- Deck Description:** Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25in. thick steel structural supports spaced at maximum 72 in. o.c. with ICHTraxx/5, ICH Traxx/4, Teks 4 or Teks 5 fasteners, The deck is fastened to the structural steel supports with fasteners applied 6 in. o.c. The deck side laps are fastened 24 in. o.c. with ICH Traxx/1 or Stitch Teks 1 fasteners.
- System Type C(6):** All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.
- Thermal Barrier:** 0.5" DensDeck® DuraGuard® Roof Board, DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board or Securock® Glass-Mat Roof Board, loose laid.
- Vapor Retarder:** WeatherWatch® XT Mat Surfaced Leak Barrier, UnderRoof™ 2 Polyester-Surfaced Leak Barrier or UnderRoof™ HT High Temperature Leak Barrier is self-adhered to the thermal barrier and rolled with a weighted roller.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2, 4, 5, 6, 7, 8	1:2 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

- Base Sheet:** Self adhere one layer of WeatherWatch® XT Mat Surfaced Leak Barrier with minimum 3" wide laps and roll with a weighted roller.
- Membrane:** One or more plies of Ruberoid® SBS Heat-Weld 25, Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap SBS Heat-Weld Plus FR with minimum 3" wide laps and torch adhered applied in accordance with manufacturer's instructions.
- Or
- Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR with minimum 3" wide laps and torch adhered in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -52.5 psf. (See General Limitation # 7)

- Membrane Type:** SBS/APP
- Deck Type 2I:** Steel, Insulated
- Deck Description:** Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports spaced at maximum 72 in. o.c. with ICH Traxx/5, ICH Traxx/4, Teks 4 or Teks 5 fasteners, The deck is fastened to the structural steel supports with fasteners applied 6 in. o.c. The deck side laps are fastened 24 in. o.c. with ICH Traxx/1 or Stitch Teks 1 fasteners.
- System Type C(7):** All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.
- Thermal Barrier:** 0.5" DensDeck® DuraGuard® Roof Board, DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board or Securock® Glass-Mat Roof Board, loose laid.
- Vapor Retarder:** Weather Watch® XT Mat Surfaced Leak Barrier, UnderRoof™ 2 Mat Surfaced Leak Barrier or UnderRoof™ HT Mat Surfaced Leak Barrier is self-adhered to the thermal barrier and rolled with a weighted roller.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick to Maximum 12" thickness.	1, 2, 4, 5, 6, 7, 8	1:1.45 ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	1, 2, 4, 5, 6, 7, 8	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

- Base Sheet:** Self adhere one layer of WeatherWatch® XT Mat Surfaced Leak Barrier with minimum 3" wide laps and roll with a weighted roller.
- Membrane:** One or more plies of Ruberoid® SBS Heat-Weld 25, Ruberoid® SBS Heat-Weld™ Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR, Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR with minimum 3" wide laps and torch adhered applied in accordance with manufacturer's instructions.
Or
Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR with minimum 3" wide laps and torch adhered in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation # 7)

Membrane Type:	APP/SBS
Deck Type 2I:	Steel, Insulated
Deck Description:	Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports spaced at maximum 72 in. o.c. with ICH Traxx/5, ICH Traxx/4, Teks 4 or Teks 5 fasteners. The deck is fastened to the structural steel supports with fasteners applied 6 in. o.c. The deck side laps are fastened 24 in. o.c. with ICH Traxx/1 or Stitch Teks 1 fasteners.
System Type C(8):	All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.
Thermal Barrier:	0.5 DensDeck® DuraGuard® Roof Board, DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board or Securock® Glass-Mat Roof Board, loose laid.
Vapor Retarder:	WeatherWatch® XT Mat Surfaced Leak Barrier, UnderRoof™ 2 Polyester-Surfaced Leak Barrier or UnderRoof™ HT High Temperature Leak Barrier is self-adhered to the thermal barrier and rolled with a weighted roller.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Securock® Gypsum-Fiber Roof Board Minimum 0.25" thick	1, 2, 4, 6, 8	1:1.6 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	Apply one layer of WeatherWatch® XT Mat Surfaced Leak Barrier self-adhered with minimum 3" wide laps and rolled with a weighted roller.
Membrane:	One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR with minimum 3" wide laps and torch adhered in accordance with manufacturer's instructions. Or Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR with minimum 3" wide laps and torch adhered in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -52.5 psf. (See General Limitation # 9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports spaced at maximum 72 in. o.c. with 0.625 in. diameter puddle welds 6 in. o.c. The deck side laps are fastened 24 in. o.c. with #12-14 x 7/8in. HWH.

System Type C(9): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: Ruberoid® Mop Smooth or Ruberoid® Mop Smooth 1.5 adhered in a full mopping (Optional) of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop Granule, Ruberoid® Mop FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: EnergyGuard™ RH Polyiso Insulation: -52.5 psf. (See General Limitation # 7)
EnergyGuard™ Polyiso Insulation: -60 psf. (See General Limitation # 7)



Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports spaced at maximum 72 in. o.c. with 0.625 in. diameter puddle welds 6 in. o.c. The deck side laps are fastened 24 in. o.c. with #12-14 x 7/8in. HWH.

System Type C(10): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:1.45 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: Ruberoid® Mop Smooth or Ruberoid® Mop Smooth 1.5 adhered in a full mopping (Optional) of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop Granule, Ruberoid® Mop FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design Pressure: -82.5 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports spaced at maximum 72 in. o.c. with 0.625 in. diameter puddle welds 6 in. o.c. The deck side laps are fastened 24 in. o.c. with #12-14 x 7/8in. HWH.

System Type C(11): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: Ruberoid® 20 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30, Ruberoid® 30 FR or Ruberoid® EnergyCap™ SBS 30 FR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports spaced at maximum 72 in. o.c. with 0.625 in. diameter puddle welds 6 in. o.c. The deck side laps are fastened 24 in. o.c. with #12-14 x 7/8in. HWH.

System Type C(12): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:1.45 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: (Optional) Ruberoid® 20 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30, Ruberoid® 30 FR or Ruberoid® EnergyCap™ SBS 30 FR, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -75 psf. (See General Limitation # 7)



Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type C(13): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: Ruberoid® Mop Smooth or Ruberoid® Mop Smooth 1.5 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

(Optional)

Membrane: Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, Ruberoid® Mop Plus, Ruberoid® Mop 170 FR, Ruberoid® Mop FR or Ruberoid® EnergyCap™ Mop FR is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation # 9)



Membrane Type:	SBS
Deck Type 2I:	Steel, Insulated
Deck Description:	Minimum 22 ga., 33 ksi
System Type C(14):	All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.
Thermal Barrier: (Optional)	Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A

Note: Base layer insulation is Minimum 2 in. when top insulation layer is Minimum 2 in.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²
EnergyGuard™ Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:3.2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.
Ply Sheet:	One Ply of Ruberoid® 20 is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
Membrane:	Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® EnergyCap™ SBS 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, Ruberoid® Mop Plus, Ruberoid® Mop 170 FR, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR or Ruberoid® EnergyCap™ 30 FR is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation # 9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type C(15): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A

Note: Base layer insulation is Minimum 2 in. when top insulation layer is Minimum 2 in.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²
EnergyGuard™ Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:3.2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One Ply of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation # 9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type C(16): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Note: Base layer insulation is Minimum 2 in. when top insulation layer is Minimum 2 in.		
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²
EnergyGuard™ Polyiso Insulation Minimum 2" thick	1, 2, 3, 4, 5, 6, 7	1:3.2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: Two plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation # 9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi

System Type C(17): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation		
Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board		
Minimum 0.25" thick	1, 2, 3, 4, 7, 8	1:4 ft ²
DensDeck® DuraGuard® Roof Board		
Minimum 0.25" thick	1, 2, 3, 4, 7, 8	1:2.67 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30 FR, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation # 9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, type B, wide rib steel deck, Grade 33 secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with Traxx/4, Traxx/5, Teks 4 or Teks 5 fasteners. The deck side laps are fastened 24 in. o.c. with Traxx/1 or Teks 1 Fasteners.

System Type C(18): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board, DensDeck® DuraGuard® Roof Board Minimum 0.5" thick	1, 2, 3, 4, 7, 8	1:2 ft ²
DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board, DensDeck® DuraGuard® Roof Board Minimum 0.5" thick	1, 2, 3, 4, 7, 8	1:1.6 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30 FR, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation # 7) for 1:2 ft² fastener density
 -82.5 psf. (See General Limitation # 7) for 1:1.6 ft² fastener density

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 80 or Minimum 20 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with Traxx/4, Traxx/5, Teks 4 or Teks 5 fasteners. The deck side laps are fastened 24 in. o.c. with Traxx/1 or Teks 1 Fasteners.

System Type C(19): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board, DensDeck® DuraGuard® Roof Board Minimum 0.5" thick	1, 2, 3, 4, 7, 8	1:1.6 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30 FR, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -90 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 80 or Minimum 20 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with Traxx/4, Traxx/5, Teks 4 or Teks 5 fasteners and 3/4" washers. The deck side laps are fastened 24 in. o.c. with Traxx/1 or Teks 1 fasteners and 3/4" washers.

System Type C(20): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation		
Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck® Prime® Roof Board, Securock® Gypsum-Fiber Roof Board, DensDeck® DuraGuard® Roof Board		
Minimum 0.5" thick	1, 2, 3, 4, 7, 8	1:1.45 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
One or two plies of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30 FR, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ Mop 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -97.5 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with #12 ICH Traxx/4, ICH Traxx/5, #12 HWH Tek 4 or HWH Tek 5. The deck side laps are fastened 24 in. o.c. with #10 HWH Tek 1 or #10 HWH Tek 3 Fasteners.

System Type C(21): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Membrane: Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -52.5 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with #12 ICH Traxx/4, ICH Traxx/5, #12 HWH Tek 4 or HWH Tek 5. The deck side laps are fastened 24 in. o.c. with #10 HWH Tek 1 or #10 HWH Tek 3 Fasteners.

System Type C(22): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One ply of Ruberoid® 20, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -52.5 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with #12 ICH Traxx/4, ICH Traxx/5, #12 HWH Tek 4 or HWH Tek 5. The deck side laps are fastened 24 in. o.c. with #10 HWH Tek 1 or #10 HWH Tek 3 Fasteners.

System Type C(23): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 3" thick to Maximum 12" thickness.	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One ply of Ruberoid® 20, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation # 7)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33

System Type C(24): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board
or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 3" thick to Maximum 12" thickness.	1, 2, 3, 4, 5, 6, 7	1:4 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One ply of Ruberoid® 20, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
OR
Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane is adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation # 9)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with #12 ICH Traxx/4, ICH Traxx/5, #12 HWH Tek 4 or HWH Tek 5. The deck side laps are fastened 24 in. o.c. with #10 HWH Tek 1 or #10 HWH Tek 3 Fasteners.

System Type C(25): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation Minimum 3" thick to Maximum 12" thickness.	1, 2, 3, 4, 5, 6, 7	1:1.6 ft²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One ply of Ruberoid® 20 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Ruberoid® Mop Granule or Ruberoid® Mop FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
Or
GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -82.5 psf. (See General Limitation # 7)



Membrane Type: SBS/APP

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with #12 ICH Traxx/4, ICH Traxx/5, #12 HWH Tek 4 or HWH Tek 5. The deck side laps are fastened 24 in. o.c. with #10 HWH Tek 1 or #10 HWH Tek 3 Fasteners.

System Type C(26): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Securock® Gypsum-Fiber Roof Board Minimum 0.375" thick	1, 2, 3, 4, 7	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Ply: One ply of Ruberoid® SBS Heat-Weld Smooth or Ruberoid® SBS Heat-Weld 25 torch-applied in accordance with manufacturer's instructions.

Ply Sheet: One ply of Ruberoid® SBS Heat-Weld Smooth or Ruberoid® SBS Heat-Weld (Optional) 25 torch-applied in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR, Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied in accordance with manufacturer's instructions.
Or
One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -82.5 psf. (See General Limitation # 7)

Membrane Type: SBS/APP

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 gauge, Grade 33, type B, wide rib steel deck, secured to minimum 0.25 in. thick steel structural supports 6 in. o.c. spaced at maximum 72 in. o.c. with #12 ICH Traxx/4, ICH Traxx/5, #12 HWH Tek 4 or HWH Tek 5. The deck side laps are fastened 24 in. o.c. with #10 HWH Tek 1 or #10 HWH Tek 3 Fasteners.

System Type C(27): All layers of insulation are mechanically attached to the roof deck. Membrane is adhered.

Thermal Barrier: (Optional) Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick to Maximum 12" thickness.	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Securock® Gypsum-Fiber Roof Board Minimum 0.375" thick	1, 2, 3, 4, 7	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached simultaneously using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Ply: One ply of Ruberoid® Torch Smooth or Tri-Ply® TP-4 torch-applied in accordance with manufacturer's instructions.

Ply Sheet: (Optional) One ply of Ruberoid® Torch Smooth or Tri-Ply® TP-4 torch-applied in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -82.5 psf. (See General Limitation # 7)

Membrane Type: APP/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18-22 ga. steel Type B Grade E steel decking attached to steel supports spaced 6 ft. o.c. with Buildex Traxx/4 or 5 fasteners spaced 6" o.c. (at the bottom flute), and with side laps attached with Buildex Traxx/1 fasteners spaced at max. of 30" o.c.

System Type C(28): All layers of insulation simultaneously fastened, perforated base sheet loose laid over the insulation with additional membranes adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 2" thick	2, 6	1:1.5 ft ²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS #80 Ultima™ Base Sheet, Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Granule, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.
Or
One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied or applied with an approved hot air welder in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -60 psf. (See General Limitation #7.)

Membrane Type: APP/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18-22 ga. steel Type B Grade 80 steel decking secured to minimum 1/4" steel supports spaced 6 ft. o.c. with Buildex Traxx/4 or 5 fasteners spaced 6" o.c. (at the bottom flute), and with side laps attached with Buildex Traxx/1 fasteners spaced at max. of 24" o.c.

System Type C(29): All layers of insulation simultaneously fastened, perforated base sheet loose laid over the insulation with additional membranes adhered.

All General and System limitations apply.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 2" thick	1, 2 & 6	1:1.45 ft ²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry, with 2" side laps.

Ply Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: Maximum two plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP-4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or Ruberoid® EnergyCap™ Torch Granule FR torch applied in accordance with manufacturer's instructions.

Or

Maximum two plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR applied with an approved hot air welder in accordance with manufacturer's instructions.

Or

(Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).) GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -67.5 psf. (See General Limitation #7.)

Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. steel, 33 ksi

System Type C(30): All layers of insulation simultaneously fastened, perforated base sheet loose laid over the insulation with additional membranes adhered.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board
 or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	1, 2, 3, 4, 5, 6, 7	1:2 ft ²

Note: All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed above. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet loose laid dry with 2" side laps.

Ply Sheet: One ply of Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Or

Two or three plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4 or GAFGLAS® FlexPly™ 6 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Or

(Required to only use with Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 ply sheet(s).) GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: APP/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18-22 ga. steel

System Type D(1): Insulation and Base sheet simultaneously attached

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® (Optional) DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation Minimum 0.75" thick	N/A	N/A
Securock® Gypsum-Fiber Roof Board Minimum 0.5" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed below. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Stratavent® Eliminator™ Nailable Venting Base Sheet, Ruberoid® SBS Heat-Weld 25, Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth applied over the loose laid insulation with 2" side laps fastened as specified below:

Drill Tec™ #12 Fastener or Drill-Tec™ #14 Fastener and Drill-Tec™ 3" Steel Plate or Drill-Tec™ AccuTrac® Flat Plates are installed through the base sheet and insulation in 4 rows 12" on center. One row is in the 2" side lap. The other two rows are equally spaced approximately 12" o.c. in the field of the sheet.

**Ply Sheet:
(Optional)** One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6 or GAFGLAS® #80 Ultima™ Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® Torch Smooth, Tri-Ply® TP-4, Ruberoid® Torch Granule, Ruberoid® Torch 180, RoofMatch™ APP Modified Granular, Tri-Ply® TP 4G, Ruberoid® Torch FR, Ruberoid® EnergyCap™ Torch Plus FR or torch applied in accordance with manufacturer's instructions.

Or

One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch applied or applied with an approved hot air welder in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)

Membrane Type: SBS/SBS Cold Applied

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18-22 ga. steel

System Type D(2): Insulation and Base sheet simultaneously attached

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, DensDeck® (Optional) DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation Minimum 0.75" thick	N/A	N/A
Securock® Gypsum-Fiber Roof Board Minimum 0.5" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and optional thermal barrier (when present) shall be mechanically attached using the fastener density listed below. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Stratavent® Eliminator™ Nailable Venting Base Sheet, Ruberoid® SBS Heat-Weld 25, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth applied over the loose laid insulation with 2" side laps fastened as specified below:

Drill-Tec™ #12 Fastener or Drill-Tec™ #14 Fastener and Drill-Tec™ 3" Steel Plate or Drill-Tec™ AccuTrac® Flat Plates are installed through the base sheet and insulation in 3 rows 12" on center. One row is in the 2" side lap. The other two rows are equally spaced approximately 12" o.c. in the field of the sheet.

Ply Sheet: One or more plies of GAFGLAS® Ply 4, Tri-Ply® Ply 4, GAFGLAS® FlexPly™ 6 or (Optional) GAFGLAS® #80 Ultima™ Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied with accordance to manufacturer's instructions.

- Membrane:** One or more plies of Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. in accordance with manufacturer's instructions.
- Or
- One or more plies of Ruberoid® 20, Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered with Matrix 102 SBS Membrane Adhesive at an application rate of 1-2 gal./sq. in accordance with manufacturer's instructions.
- Surfacing:** **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**
1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
 2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
 3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.
- Maximum Design Pressure:** -45 psf. (See General Limitation #9)

Membrane Type: SBS Cold Applied

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 18, 20, 22 ga. type B grade 33, wide rib, 1.5 in. deep new steel deck secured to minimum 0.25 in. thick structural supports spaced 6' o.c. at maximum with Teks 4, Teks 5, ICH Traxx/4 or ICH Traxx/5 fasteners spaced maximum 6 in. o.c. along each support. Deck side laps are fastened with Stitch Teks 1 or ICH Traxx/1 fasteners spaced 24 in. o.c. at maximum.

System Type D(3): Insulation is loose laid; base sheet is mechanically fastened through insulation to the roof deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System Limitations shall apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and optional thermal barrier (when present) shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Stratavent® Eliminator™ Nailable Venting Base Sheet, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth mechanically attached through the insulation to the steel deck with Drill-Tec™ #12 Fasteners or Drill-Tec™ #14 Fasteners and Drill-Tec™ AccuTrac® Flat Plates, AccuTrac® Recessed Plates, Drill-Tec™ 3" Standard Steel Plates, or Drill-Tec™ 3" Steel Plates spaced 6 in. o.c. within the minimum 3.5 in. wide side laps and 12 in. o.c. in the field of the sheet in three staggered rows. Base sheet side laps and fastener rows are perpendicular to the direction of the steel deck ribbing.

Ply Sheet: One or more plies of Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered to the base sheet with minimum 4 in. wide laps with Matrix™ 102 SBS Membrane Adhesive applied at total rate of 2 gal./sq. The base ply/adhesive/base sheet combination is permitted to cure overnight.

Membrane: One or more plies of Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR, Ruberoid® EnergyCap™ SBS 30 FR SBS Membrane adhered to the base ply with Matrix 102 SBS Membrane adhesive applied at a total rate of 2 gal./sq. The side laps are minimum 3.75 in. wide and sealed with minimum 3.75 in. wide heat welds positioned on the outer edge of the laps. The end laps are minimum 6 in wide and sealed with Matrix 102 SBS Membrane Adhesive applied at a total rate of 2 gal./sq. applied in accordance with manufacturer's instructions

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -82.5 psf. (See General Limitation #7)

Membrane Type: SBS Heat-Weld

Deck Type 2I: Steel

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/5 screws spaced at 6 in o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(4): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation , EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Ply: One of the following Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth fastened to the deck with Drill-Tec™ #12 Fasteners, Drill-Tec™ AccuTrac® Flat Plates, AccuTrac® Recessed Plates or Drill-Tec™ 3" Standard Steel Plates spaced 6 in o.c. through the minimum 3.25 in wide side laps.

Membrane: One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torched adhered or applied with an approved hot air welder with minimum 3 in wide laps. in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -112.5 (See General Limitation # 7)



Membrane Type: SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 was secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/5 screws spaced at 6 in o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(5): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Ply: One ply of the following Ruberoid® Mop Smooth, Ruberoid® Mop Plus Smooth or Ruberoid® Mop Smooth 1.5 fastened to the deck with Drill-Tec™ AccuTrac® Flat Plates and Drill-Tec™ 3" Standard Steel Plates with Drill-Tec™ #12 Fasteners spaced 12 in. o.c. through the minimum 3.5 in. wide side laps.

Membrane: One or more plies of Ruberoid® SBS Heat-Weld Smooth, Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torched adhered or applied with an approved hot air welder with minimum 3 in wide laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -52.5 (See General Limitation # 7)



NOA No.: 13-1022.16
Expiration Date: 11/06/15
Approval Date: 10/16/14
Page 95 of 110

Membrane Type: SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/5 screws spaced at 6 in. o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(6): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation Minimum 1.5" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Ply: One ply of Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth fastened to the deck with Drill-Tec™ #12 Fasteners and Drill-Tec™ 3" Standard Steel Plates or Drill-Tec™ ASAP S3 spaced 18 in o.c. through the minimum 3.25 in. wide side laps and in two staggered rows in the field of the sheet.

Ply Sheet: Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-25 lbs./sq. applied in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -82.5 (See General Limitation # 7)

Membrane Type: SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/5 screws spaced at 6 in. o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(7): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation Minimum 0.75" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: GAFGLAS® #75 Base Sheet, Tri-Ply® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet or GAFGLAS® Stratavent® Eliminator™ Nailable Venting Base Sheet applied over the loose laid insulation with 2" side laps fastened with Drill-Tec™ #12 Fastener or Drill-Tec™ #14 Fastener and Drill-Tec™ 3" Steel or or Drill-Tec™ ASAP S3 installed through the base sheet and insulation maximum 18" o.c. through the minimum 2 in. wide side laps and in 3 rows staggered in the field on the sheet at max. 18 in. o.c.

Ply Sheet: One or more plies of Ruberoid® 20, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Membrane: One or more plies of Ruberoid® 30, Ruberoid® 30 FR, Ruberoid® Mop Granule, Tri-Ply® SBS Modified Bitumen Membrane, RoofMatch™ SBS Modified Granular, Intec Flex PRF, Ruberoid® Mop Smooth, Ruberoid® Mop Smooth 1.5, Ruberoid® Mop Plus Smooth, Ruberoid® Mop Plus, Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ 30 FR SBS Membrane adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 (See General Limitation # 9)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type D(8): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or
3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation Minimum 0.75" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard Roof Insulation, EnergyGuard™ Perlite Recover Board, EnergyGuard™ HD Polyiso Insulation or EnergyGuard™ HD Plus Polyiso Insulation Minimum 0.5" thick	N/A	N/A
Securock® Glass-Mat Roof Board, DensDeck® Roof Board Minimum 0.25" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Ruberoid® Mop Smooth 1.5 fastened to the deck with Drill-Tec™ #12 or #14 Fasteners and Drill-Tec™ 2 in. Barbed Plates located off-centered in the lap by 0.5 in. towards the edge of the sheet and spaced maximum 18 in. o.c. within the 4 in. wide side laps. The Minimum 4 in. wide side laps are spaced maximum 35.625" o.c. and are torched or hot air welded.

Membrane: One or more plies of Ruberoid® Mop FR, Ruberoid® Mop 170 FR or Ruberoid® EnergyCap™ Mop FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.
OR
Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR or torch adhered with minimum 3 in. wide laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 (See General Limitation # 9)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga., 33 ksi.

System Type D(9): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board,
(Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or
3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation, Minimum 0.75" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard Roof Insulation, EnergyGuard™ Perlite Recover Board, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation. Minimum 0.5" thick	N/A	N/A
Securock® Glass-Mat Roof Board, DensDeck® Roof Board Minimum 0.25" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth fastened to the deck with Drill-Tec™ Batten Bars centered in the 4 in. wide side laps and Drill-Tec™ #12 or #14 Fasteners spaced maximum 18 in. o.c. along the batten bar. The Minimum 4 in. wide side laps are spaced maximum 35.625" o.c. and are torched or hot air welded.

Membrane: One or more plies of Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR or Ruberoid® Mop 170 FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.
OR
Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR or torch adhered with minimum 3 in. wide laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS[®] Mineral Surfaced Cap Sheet, Tri-Ply[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™] BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat[®] Membrane, Topcoat[®] MB Plus (to be used as a primer with Topcoat[®] Membrane) or Topcoat[®] Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -45 (See General Limitation # 9)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/4, Traxx/5, Teks 4 or Teks 5 screws spaced at 6 in. o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(10): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Perlite Roof Insulation, Minimum 0.75" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard Roof Insulation, EnergyGuard™ Perlite Recover Board, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation. Minimum 0.5" thick	N/A	N/A
Securock® Glass-Mat Roof Board, DensDeck® Roof Board Minimum 0.25" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth fastened to the deck with Drill-Tec™ Batten Bars centered in the 4 in. wide side laps and Drill-Tec™ XHD Fasteners spaced maximum 12 in. o.c. along the batten bar. The Minimum 4 in. wide side laps are spaced maximum 35.625" o.c. and are torched or hot air welded.

Membrane: One or more plies of Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR or Ruberoid® Mop 170 FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

OR

Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch adhered with minimum 3 in. wide laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -67.5 (See General Limitation # 7)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/4, Traxx/5, Teks 4 or Teks 5 screws spaced at 6 in. o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(11): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation, Minimum 0.75" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard Roof Insulation, EnergyGuard™ Perlite Recover Board, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation. Minimum 0.5" thick	N/A	N/A
Securock® Glass-Mat Roof Board, DensDeck® Roof Board Minimum 0.25" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth fastened to the deck with Drill-Tec™ 2 in. Barbed Plates and Drill-Tec™ XHD Fasteners located off-centered in the lap by 0.5 in. towards the edge of the sheet and spaced maximum 12 in. o.c. within the minimum 4 in. wide side laps. The Minimum 4 in. wide side laps are spaced maximum 35.625" o.c. and are torched or hot air welded.

Membrane: One or more plies of Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR or Ruberoid® Mop 170 FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Or

Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch adhered with minimum 3 in. wide laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -52.5 (See General Limitation # 7)

Membrane Type: SBS/SBS Heat-Weld

Deck Type 2I: Steel, Insulated

Deck Description: Minimum 22 ga. type B, wide rib steel deck, grade 33 secured to 0.25 in. (6.4 mm) thick structural supports spaced at 6' o.c. using Traxx/4, Traxx/5, Teks 4 or Teks 5 screws spaced at 6 in. o.c. and with side laps secured with Traxx/1 screws spaced at 24 in. o.c.

System Type D(12): Insulation is loose laid; preliminary attachment to deck.

Thermal Barrier: Minimum 1/4" DensDeck® Roof Board, DensDeck® Prime® Roof Board, (Optional) DensDeck® DuraGuard® Roof Board; 1/2" Securock® Gypsum-Fiber Roof Board or 3/4" EnergyGuard™ Perlite Roof Insulation loose laid on steel deck.

All General and System limitations apply.

One or more layers of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ Perlite Roof Insulation, Minimum 0.75" thick	N/A	N/A
Structodek® High Density Roofing Fiberboard Roof Insulation, EnergyGuard™ Perlite Recover Board, EnergyGuard™ HD Polyiso Insulation, EnergyGuard™ HD Plus Polyiso Insulation. Minimum 0.5" thick	N/A	N/A
Securock® Glass-Mat Roof Board, DensDeck® Roof Board Minimum 0.25" thick	N/A	N/A

Note: Insulation shall have preliminary attachment, prior to the installation of the base sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation, optional thermal barrier (when present) and base sheet shall be simultaneously fastened. See base sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Ruberoid® Mop Smooth 1.5 or Ruberoid® Mop Plus Smooth fastened to the deck with Drill-Tec™ 2 3/8 in. Barbed XHD Plates and Drill-Tec™ XHD Fasteners located off-centered in the lap by 0.25 in. towards the edge of the sheet and spaced maximum 12 in. o.c. within the minimum 5 in. wide side laps. The Minimum 5 in. wide side laps are spaced maximum 35.625" o.c. and are torched or hot air welded.

Membrane: One or more plies of Ruberoid® Mop FR, Ruberoid® EnergyCap™ Mop FR or Ruberoid® Mop 170 FR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. applied in accordance with manufacturer's instructions.

Or

Ruberoid® SBS Heat-Weld Granule, Ruberoid® SBS Heat-Weld 170 FR, Ruberoid® SBS Heat-Weld Plus, Ruberoid® SBS Heat-Weld Plus FR or Ruberoid® EnergyCap™ SBS Heat-Weld Plus FR torch adhered with minimum 3 in. wide laps in accordance with manufacturer's instructions.

Surfacing: **Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions. All coatings must be listed within a current NOA.**

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.
2. GAFGLAS® Mineral Surfaced Cap Sheet, Tri-Ply® Mineral Surfaced Cap Sheet or GAFGLAS® EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
3. Topcoat® Membrane, Topcoat® MB Plus (to be used as a primer with Topcoat® Membrane) or Topcoat® Surface Seal SB applied at 1 to 1.5 gal./sq.

Maximum Design

Pressure: -67.5 (See General Limitation # 7)

STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 13-1022.16
Expiration Date: 11/06/15
Approval Date: 10/16/14
Page 110 of 110